

This file has been cleaned of potential threats.

To view the reconstructed contents, please SCROLL DOWN to next page.



प्लाज्मा अनुसंधान संस्थान  
INSTITUTE FOR PLASMA RESEARCH  
परमाणु ऊर्जा विभाग, भारत सरकार का एक सहायता प्राप्त  
संस्थान  
An Aided Institute of Department of Atomic Energy,  
Government of India



इन्दिरा पुल के पास, भट, गांधीनगर - 382 428 भारत  
दूरभाष: (079) 2396 2020/2021/2028  
फैक्स: 91-079-23962277  
वेब: [www.ipr.res.in](http://www.ipr.res.in)

NEAR INDIRA BRIDGE, BHAT  
DIST. GANDHINAGAR - 382 428 (INDIA)  
Phone: (079) 2396 2020/2021/2028  
Fax : 91-079-23962277  
Web : [www.ipr.res.in](http://www.ipr.res.in)

## ENQUIRY

ENQUIRY NO : IPR/EQL/18-19/083  
Date : 14-06-2018

**Due on : 12-07-2018 by 1:00 PM IST**

Please send your offer in sealed envelope specifying Enquiry No, Date & Due Date, ALONG WITH your credentials for the following items:

### Important Note:

Please note that e-mail quotations are not acceptable however you may send your queries (if any) to [localpurchase@ipr.res.in](mailto:localpurchase@ipr.res.in)

Please ensure your sealed quotation reaches this office not later than above mentioned due date and time.

Kindly go through the following documents properly before quoting which are available on the IPR web portal i.e., [http://www.ipr.res.in/documents/tender\\_terms.html](http://www.ipr.res.in/documents/tender_terms.html) / attached herewith.

- 1) Instructions to the bidders & Terms and conditions (refer Form No: IPR-LP-01.V4)
- 2) Bidding format

**GST for Goods and Services (IGST/CGST/SGST TAX BENEFITS):** Please refer clause no: 8 of Form No: IPR-LP-01.V4

### QUOTATION SHOULD BE ADDRESSED TO PURCHASE OFFICER ONLY

Sr No	Description	Quantity
1	Industrial Air cooler (Detailed specification has been attached)	2.0 Nos.

Note: -

Encl: As per attachment.

Sd/-

Mr. D. Ramesh  
Purchase Officer-II

**Information to Vendors:** We are working towards a single platform for our future requirement. Hence, please refer IPR website i.e, <http://www.ipr.res.in/documents/tenderseng.html> for our future requirement.

✓

**Technical Specification for supply of Industrial Air cooler for cooling of Air compressor**

<b>Sr. No.</b>	<b>Technical Specification</b>	<b>Vendor Specification with values and descriptions</b>
1	Motor :Single Phase, Possibility of Speed variation -3 Speed	
2	Power Supply:230V AC,50Hz	
3	Fan type: Axial Fan	
4	Fan Material: Aluminium	
5	Fan Noise: ~70 dB	
6	Fan speed : ~950RPM	
7	Maximum Current : ~2.5 Amp	
8	Wattage: ~490W	
9	Air Flow: ~15000 m <sup>3</sup> /h	
10	Cooling Area: ~2000 sq.ft	
11	Water Tank Capacity: ~100 Litres	
12	The equipment should have Automatic OR Manual Water inlets	
13	The equipment should have Wheels and Brakes for movement and locking	
14	The equipment should have provision of full function remote control operation with timer	
15	One year warranty from the date of delivery of the equipment.	

**NOTE:**

- (1) User's manual has to be submitted along with the equipment.
- (2) Acceptance for delivery of the equipment has been given after pre dispatch. Inspection for its performance by the IPR representative at the vendor's site.