

This file has been cleaned of potential threats.

To view the reconstructed contents, please SCROLL DOWN to next page.



प्लाज्मा अनुसंधान संस्थान
INSTITUTE FOR PLASMA RESEARCH
परमाणु ऊर्जा विभाग, भारत सरकार का एक सहायता प्राप्त
संस्थान
An Aided Institute of Department of Atomic Energy,
Government of India



इन्दिरा पुल के पास, भट, गांधीनगर - 382 428 भारत
दूरभाष: (079) 2396 2020/2021/2028
फैक्स: 91-079-23962277
वेब: www.ipr.res.in

NEAR INDIRA BRIDGE, BHAT
DIST. GANDHINAGAR - 382 428 (INDIA)
Phone: (079) 2396 2020/2021/2028
Fax : 91-079-23962277
Web : www.ipr.res.in

ENQUIRY

ENQUIRY NO : IPR/EQL/18-19/130
Date : 24-07-2018

Due on : 23-08-2018 by 1:00 PM IST

Please send your offer in sealed envelope specifying Enquiry No, Date & Due Date, ALONG WITH your credentials for the following items:

Important Note:

Please note that e-mail quotations are not acceptable however you may send your queries (if any) to localpurchase@ipr.res.in

Please ensure your sealed quotation reaches this office not later than above mentioned due date and time.

Kindly go through the following documents properly before quoting which are available on the IPR web portal i.e., http://www.ipr.res.in/documents/tender_terms.html / attached herewith.

- 1) Instructions to the bidders & Terms and conditions (refer Form No: IPR-LP-01.V4)
- 2) Bidding format

GST for Goods and Services (IGST/CGST/SGST TAX BENEFITS): Please refer clause no: 8 of Form No: IPR-LP-01.V4

QUOTATION SHOULD BE ADDRESSED TO PURCHASE OFFICER ONLY

Sr No	Description	Quantity
1	Supply of 5/8 inch soft copper tube for Split AC with nitrile insulation of 'O' - Class fire rating extruded tube section.	100.0 Mtrs.
2	Supply of 3/8 inch soft copper tube for Split AC with nitrile insulation of 'O' - Class fire rating extruded tube section.	100.0 Mtrs.
3	Supply of 1/2 inch soft copper tube for Split AC with nitrile insulation of 'O' - Class fire rating extruded tube section.	100.0 Mtrs.
4	Supply of 1/4 inch soft copper tube for Split AC with nitrile insulation of 'O' - Class fire rating extruded tube section.	100.0 Mtrs.

Note: -

Encl: As per attachment.

Sd/-

Mr. D. Ramesh
Purchase Officer-II

Information to Vendors: We are working towards a single platform for our future requirement. Hence, please refer IPR website i.e, <http://www.ipr.res.in/documents/tenderseng.html> for our future requirement.

✓ ✓

Technical specification for Copper tube and Nitrile Insulation:

Description for Copper tube: IPR Spec.

Type : Soft Copper Tube
Make : Parasmani / Totaline / Mandev / Rajco / Mexflow.

Description for Nitrile Insulation: IPR Spec.

Material : Nitrile rubber sleeve
Make : Armaflex / Kflex / Equivalent
Class : 'O' - class fire rating
Type : Extruded tube section
Thickness : 9 mm
ID of nitrile insulation : Standard size, suitable to copper tube OD.

Data sheet of copper tube and Nitrile insulation

For Copper tube		
Description	IPR Spec.	Data to be filled by vendor
Type	Soft Copper Tube	
Make	Parasmani / Totaline / Mandev / Rajco / Mexflow.	

For Nitrile insulation		
Description	IPR Spec.	Data to be filled by vendor
Material	Nitrile rubber sleeve	
Make	Armaflex / Kflex / Equivalent	
Class	'O' - class fire rating	
Type	Extruded tube section	
Thickness	9 mm	
ID of nitrile insulation	Standard size, suitable to copper tube OD.	